1 ATTACHMENT D-4 2 EDS AIR FILTRATION SYSTEM CARBON FILTER PERFORMANCE

Date: October 2013 Revision No. 0

1

(This page intentionally left blank.)

Revision No. 0

1		ATTACHMENT D-4
2		EDS AIR FILTRATION SYSTEM CARBON FILTER PERFORMANCE
3		
4	1.	INTRODUCTION
5		
6	1.1	Purpose
7		
8	Two l	Explosive Destruction System (EDS) units will be located at the Pueblo Chemical Agent-Disposal
9	Pilot l	Plant (PCAPP) Explosive Destruction System (EDS) site, Pueblo Chemical Depot, Colorado. Each
10	EDS 1	unit will be located inside an Environmental Enclosure that provides weather protection and interior
11	enviro	onmental control for worker comfort and safety. Each enclosure will have two Air Filtration
12	Syste	ms (AFSs). Each AFS includes prefilter, high efficiency particulate air (HEPA) filters (2),
13	sulfur	-impregnated carbon (SIC) high efficiency gas adsorber (HEGA) filters (2), and an induced draft
14	fan to	maintain a negative pressure within the structure relative to the outside air and to capture vapors
15	that n	nay result from handling and treatment operations.
16		
17	This a	attachment contains a description of an enclosure AFS and carbon filter unit components plus
18	calcul	ations on carbon filter performance. The purpose of the calculations is to predict how the carbon
19	filter	will perform during a catastrophic event.
20		
21		 Appendix Attachment D-4-1 contains a list of acronyms and abbreviations.
22		
23		 Appendix Attachment D-4-2 details the calculations for the catastrophic release
24		scenario.
25		
26		• Appendix Attachment D-4-3 is a list of references.
27		
28	A des	cription of the EDS and treatment operation is provided in Section D of the permit modification.
29	Musta	ard chemical agents distilled sulfur mustard (HD)/mustard-T mixture (HT) will be treated at the
30	PCAF	PP EDS site.

Date: October 2013 Revision No. 0

1.2	Backgrour	ıd
-----	-----------	----

1	
_	
2	

- 3 An Environmental Enclosure surrounds the EDS. The AFS provides negative pressure ventilation for the
- 4 enclosure and filters air from the enclosure before it is released to the environment. Gases from the EDS
- 5 treatment process are vented via a duct to the AFS. The release of gases from the EDS to the AFS is a
- 6 controlled process and is not performed until the treatment level has been reached. Therefore, the amount
- of chemical agent released from the EDS to the AFS is negligible. The greatest potential for agent
- 8 challenge to the AFS would be if a munition were to leak while inside the Environmental Enclosure, but
- 9 before it has been sealed inside the EDS Containment Vessel.

10

- The AFS consists of a prefilter, a HEPA filter, two HEGA filter banks in series, another HEPA filter, and
- 12 a motor-powered exhaust fan. The filter unit fan draws air from the Environmental Enclosure through the
- carbon filter unit components and subsequently discharges to the atmosphere.

14

15 The two HEGA filter banks in the enclosure AFS are composed of SIC beds.

16 17

1.3 Methodology for Evaluating Calculation Results

18

- 19 The evaluated scenario has been developed using an indoor spill scenario developed for the Federal
- 20 Emergency Management Agency and U.S. Army Chemical Stockpile Emergency Preparedness Program
- 21 (CSEPP) and presents conservative operating conditions and maximum anticipated operating parameters.

2223

1.4 EDS Safeguards

24

- 25 Safeguards and procedures have been established to ensure that: (1) filter units are operating properly
- before treatment operations begin and (2) if breakthrough occurs, necessary actions are taken to restore
- 27 filter performance. Additionally, all of the munitions to be treated will arrive at an EDS unit in either a
- 28 universal munition storage container or other containers approved for use at PCD, and will be placed in its
- 29 entirety into an EDS for treatment. The container will not be opened.

30

31 EDS safeguards include:

- Leak-testing of AFS carbon filter banks
- Midbed agent monitoring
- Carbon changeout.

1	Leak-Testing Carbon Banks
2	
3	EDS carbon filters are tested before first use, after each changeout of carbon filters, and before restarting
4	operations after a temporary closeout. Testing is in accordance with the American National Standards
5	Institute/American Society of Mechanical Engineers (ANSI/ASME) standard N511-2007, "Testing of
6	Nuclear Air Cleaning System."
7	
8	Midbed Agent Monitoring
9	
10	Operational safeguards present at the EDS provide for system reliability. As described in
11	Attachment F-2 of this permit modification, MINICAMS® and Depot Area Air Monitoring System
12	(DAAMS) confirmation monitoring will be used to monitor the enclosure AFS. The presence of
13	chemical agent mustard at the midbed is monitored continuously; the filters are replaced should
14	breakthrough be confirmed. Monitoring will be performed to provide sufficient warning so that
15	corrective action can be taken before a release of chemical agent occurs.
16	
17	Carbon Changeout Strategy
18	
19	Mandatory criteria have been established for changing out banks of activated carbon in the enclosure AFS
20	when chemical agent is positively detected in the midbed or exhaust monitoring locations. Carbon filters
21	will be changed out when (1) midbed monitoring confirms breakthrough of chemical agent at a
22	concentration at or above the vapor screening level (VSL) alarm level and (2) after completing EDS
23	treatment operations (Resource Conservation and Recovery Act [RCRA] closure). If a carbon midbed
24	monitoring detection is confirmed, the operation will be brought to a safe shutdown state. The first
25	carbon filter will be removed and disposed of, the second carbon filter will be moved to the first, and a
26	new carbon filter will be added as the second filter. All filters will be leak checked in accordance with
27	the ANSI N511-2007 standard before processing may resume. The in-place leak tests ensure mechanical
28	integrity of the filter units before bringing them back into service after the carbon changeout.
29	
30	2. CALCULATION METHOD
31	
32	Vapor emission rates are calculated based on physical properties and process parameters. The emission
33	period for vapors will be scenario-specific, but a time sequence for operation, monitoring, and
34	performance of corrective actions will be postulated. Termination of the emission event will be
35	recognized when engineering containment of the release is re-established.

Date: October 2013 Revision No. 0

3. CALCULATION SCENARIO

The following scenario was considered:

• Catastrophic release of mustard agent (H)¹ within the EDS enclosure from the rupture of a munition outside the EDS Containment Vessel.

Calculations for this scenario are presented in **Appendix Attachment D-4-2** of this attachment.

3.1 Catastrophic Scenario

The catastrophic scenario evaluated is the accidental release of H, the fill material present in all of the items to be treated in the EDS. The spill size was assumed to be the entire contents of the largest item expected to contain that fill and be brought into the EDS enclosure. It was assumed that the spilled liquid formed a pool 0.1 centimeter deep that was open to the room (as opposed to being contained in a sump).

The largest H-filled item is a 155mm projectile, which could contain up to 11.7 pounds (lbs) (0.148 cubic feet) of H (SciTech, 1998). This amount of H fill (11.7 lbs) equates to approximately 7.6 lbs (0.096 cubic feet) of liquid mustard agent, as the rest is solid heel. After being placed into a munition, H forms a heel of solid material, which no longer being liquid would not flow from the munitions. A study of 155mm H-filled munitions revealed that the average munition contained 39 percent heel while the median value was 32 percent. Therefore, a heel value of 35 percent was used for these calculations (PMCD, 2011). It is assumed that 1 hour is needed for the spilled material to be contained and that the temperature of the spilled material is 21.1°C (70°F). Based on these assumptions, the filter challenge is calculated to be the amount of agent that would be adsorbed by the carbon filter in 60 minutes at 21.1°C (70°F). The minute by minute iterative calculations showed that only 0.02273 lb of H was transferred to the carbon filter in 60 minutes and 0.02271 lb was adsorbed by the carbon filter with 99.9 percent mechanical efficiency.

3.2 Calculations

- **Catastrophic Scenario.** The catastrophic emission scenario calculations are presented in
- 32 Appendix Attachment D-4-2.

HD/HT are measured as H.

1	4.	RESULTS
2		
3	4.1	Catastrophic Emission
4		
5	4.1.1	H Scenario. The evaporation for H was calculated to be 68.6 milligrams per minute (mg/min)
6	per squ	hare meter (m ²) (or 185 mg/min based on 2.699 m ² pool area). A mass of 0.02273 lb of H was
7	transfe	rred to the carbon filter during the 60 minutes after the spill. The amount adsorbed by the carbon
8	filter w	vas 0.02271 lb during these 60 minutes. Thus, the emissions from the carbon filter would be
9	0.0000	23 lb in the first 60 minutes after the spill. The maximum concentration in the exhaust air was
10	estima	ted to be 0.000982 milligram per cubic meter (mg/m³) during this 60-minute period. Based on a
11	carbon	filter capacity for H of 0.2 gram (g) of H per g of carbon, the total filter capacity (assuming
12	4,000 p	bounds of carbon) is approximately 800 lbs of H. The filter is capable of handling more than
13	35,195	H maximum credible events (MCEs) without breakthrough. Therefore, the catastrophic event
14	would	not result in breakthrough of the carbon filter.
15		
16	5.	CONCLUSIONS
17		
18	The ca	rbon filter unit used in the enclosure AFS was specifically designed for chemical agent processing
19	operati	ons and is more than adequate to handle normal as well as catastrophic releases as shown by
20	calcula	tions. The use of this filtration system, in addition to EDS Standing Operating Procedures, will
21	ensure	that normal EDS operations with accidental spills pose little threat to human health and the
22	enviro	nment.
23		
24	The ca	lculations for an unlikely catastrophic release of H within the EDS enclosure indicate that the
25	enclosi	ure AFS has sufficient capacity to contain H vapors without breakthrough of the AFS. The filter
26	challer	age from the H catastrophic scenario was determined to be 0.02273 lb of H and the filter capacity
27	for H v	vas calculated to be 800 lbs of H.
28		
29	The ma	aximum 1-minute emission rate for H leaving the AFS is 0.000982 mg/m³, which is less than the
30	source	emission limit (SEL) of $0.03~\text{mg/m}^3$ and below the VSL of $0.003~\text{mg/m}^3$.

(This page intentionally left blank.)

APPENDIX ATTACHMENT D-4-1
ACRONYMS AND ABBREVIATIONS

1

Date: October 2013 Revision No. 0

1

(This page intentionally left blank.)

Date: October 2013 Revision No. 0

2		A CID ONIVARO AND A DEDUCATION OF COMME
		ACRONYMS AND ABBREVIATIONS
3		
4		
5	AFS	Air Filtration System
6	ANSI	American National Standards Institute
7	ASME	American Society of Mechanical Engineers
8		
9	cfm	cubic feet per minute
10	cm	centimeter
11	CSEPP	Chemical Stockpile Emergency Preparedness Program
12		
13	DAAMS	Depot Area Air Monitoring System
14		
15	EDS	Explosive Destruction System
16		
17	ft ³	cubic feet
18		
19	g	gram
20	g/g	gram per gram
21		
22	Н	sulfur mustard (bis(2-chloroethyl) sulfide)
23	HD	distilled sulfur mustard
24	HEGA	high efficiency gas adsorber
25	HEPA	high efficiency particulate air
26	HT	mustard-T mixture
27		
28	kg	kilogram
29		
30	lbs	pounds
31		
32	m^2	square meter
33	m/min	meter per minute
34	MCE	maximum credible event
35	mg	milligram

Date: October 2013 Revision No. 0

1	mg/min	milligram per minute
2	mg/m^3	milligram per cubic meter
3	mg/min/m ²	milligram per minute per square meter
4	mm	millimeter
5		
6	PCAPP	Pueblo Chemical Agent-Destruction Pilot Plant
7	psia	pounds per square inch absolute
8		
9	RCRA	Resource Conservation and Recovery Act
10		
11	SEL	source emission limit
12	SIC	sulfur-impregnated carbon
13		
14	VSL	vapor screening level

1	APPENDIX ATTACHMENT D-4-2
2	CATASTROPHIC RELEASE
3	MUSTARD AGENT (H)

Date: October 2013 Revision No. 0

1

(This page intentionally left blank.)

Revision No. 0

1		APPENDIX ATTACHMENT D-4-2
2		CATASTROPHIC RELEASE
3		MUSTARD AGENT (H)
4		
5		
6	1. PURPOSE	
7		
8 9		nclosure Air Filtration System (AFS) to contain chemical agent during a Explosive Destruction System (EDS) enclosure.
10		
11		or the following catastrophic release scenario: a spill of sulfur mustard (H).
12		as with the largest catastrophic potential to be brought into the EDS
13 14		initions. Therefore, assuming all the munitions are equally corroded, it is κ , it will be from an H-filled munition.
15	most fixely that if there is a real	x, it will be from all 11-timed mullition.
16	The catastrophic release scenar	io for H assumes spillage of the liquid portion of a 155mm projectile (the
17		ly to contain H) contents inside the EDS enclosure.
18		, , ,, ,
19	2. ANALYTICAL MET	HOD
20		
21	 Calculate H ch 	allenge to the AFS.
22	 Calculate H ev. 	aporation rate.
23	 Calculate mass 	of H evaporated.
24	Calculate enclo	osure AFS capacity for H.
25	 Calculate AFS 	carbon capacity safety factor and H emission rate.
26		
27	3. H SCENARIO INPUT	TS
28		
29	EDS Enclosure Volume	e (assumes Sprung Structure with 60' L x 40' W x 25' H)
30	27.100 11.0 (2.3)	
31	35,100 cubic feet (ft ³)	
32	M	000)
33	Munitions (SciTech, 19	
34 35	Type Fill	155mm projectile, M110 11.7 pounds (lbs) H
36	Heel	35%
37	Liquid H	7.6 lbs
38	Density of H	79.28 lbs/cubic foot
39	Volume of Liquid H	0.096 ft^3

Date: October 2013 Revision No. 0

1 2 3 4 5 6 7 8		Flow rate Mass of c Filter med	carbon ch. efficie ME N-510-	ncy (H)	3,325 ft ³ per minute (cfm per AFS; two AFS units operate in parallel during operations) 4,000 lbs (2,000 lbs per AFS) 99.9% 0.2 gram of H per gram (g/g) of carbon (based on Mahle, 2008)
9	4.	ASSUMI	PTIONS		
10 11 12 13 14 15 16 17 18 19 20 21 22		2. A 3. T 4. E 5. T a 6. A 7. T o 8. If	Airflow the spilled Evaporatio The spilled assumed). Ambient properties on equipment is further	rough the room material for nate is con liquid is at ressure is 14 mass of evaluation or structure.	s no interior rooms or false ceilings. com is constant and uniform. rms a pool 0.1 centimeter (cm) deep. stant over the duration of the calculation. the same temperature as the enclosure air (21.1°C [70°F] is 7.7 pounds per square inch absolute (psia). porated chemical enters the AFS; none is lost due to condensation ural surfaces. at 1 hour elapses before spill response actions are able to contain ent.
23	5.	H CALC	CULATIO	ONS	
24 25	5.1	Calculat	e H Chall	enge to Enc	closure AFS
26 27 28 29		ios develop	ped for the	Chemical S	of H. This calculation used the evaporation model for indoor spill stockpile Emergency Preparedness Program (CSEPP) (Fedele, rvative, as it provides the highest value for evaporation flux. $E = C_{\text{vol}} \times V_{\text{evap}}$
30 31 32 33 34 35 36		C	$E = C_{\text{vol}} = V_{\text{evap}} = E = E$	volatility of 21.1°C (70 evaporation (Fedele, 20	n transfer rate in meters per minute (m/min) = 0.1 m/min

Because mustard agent has about 35% heel, the liquid portion is calculated to be: 1 2 3 **Liquid Portion** Total Content (1 - % Heel/100) 4 $11.7 \times (1 - 35/100)$ = 5 7.6 lbs = 6 7 Because the spill amount is 7.6 lbs (3.45 kilograms [kg]), the pool area (A) is evaluated to be 29.04 sq. ft. 8 (2.699 m²) for H agent with density of 79.28 lbs/cubic foot and 0.039 inch (0.1 cm) pool thickness. The 9 evaporation rate (R) for the entire spill is calculated as follows: 10 ER $E \times A$ 11 12 = 68.6×2.699 13 185 mg/min 14 5.1.2 Calculate Mass of H Evaporated in 60 Minutes. 15 16 17 Mass of H evaporated in 60 minutes = $60 \text{ min} \times \text{(Evaporation Rate)}$ $60 \text{ min} \times 185 \text{ mg/min} = 11,100 \text{ mg (or } 0.0111 \text{ kg)}$ 18 Mass 19 $11,100 \text{ mg} \times 0.001 \text{ g/mg} / 454 \text{ g/lb}$ = 0.02445 lbs 20 21 22 5.1.3 Calculate Filter Capacity for H. 23 24 Filter Capacity (Carbon Capacity) × (Mass of Carbon) = $0.2 \text{ lb/lb} \times 4.000 \text{ lb} = 800 \text{ lbs}$ 25 Capacity 26 27 Calculate AFS Carbon Capacity Safety Factor and Emission Rate. 5.1.4 28 29 Amount transferred to filter in one hour = 0.02273 lbs 30 (By iterative calculations) 31 32 Amount adsorbed in AFS carbon filters = (Mass Rate of H Entering Filter in 1 hour) × (% Filter Efficiency/100) 33 $= 0.02273 \text{ lbs/hr} \times 0.999$ 34 35 $= 0.02271 \, lbs/hr$ 36 37 **Emission Rate** (Mass Rate of H Entering Filter in 1 hour) × (1 - % Filter Efficiency/100) 38 **Emission Rate** $0.02273 \text{ lbs/hr} \times (1-0.999)$ = 39 0.000023 lbs/hr

40 41

42

Note: Mass rate entering the filter is calculated by evaluating the gas concentration in the room as a function of time. This concentration changes as long as there is a difference between the amount evaporated in a minute and the amount transferred to the carbon filter.

43 44 45

The filter capacity (800 lbs) is greater (by a factor of about 35,195) than the size of the H challenge (0.02273 lb/hr). Therefore, the filter is able to contain the challenge without reaching breakthrough for H.

46 47 48

6. **CONCLUSION**

49 50

51

As shown by calculation, the enclosure AFS has sufficient capacity that the H released from the catastrophic spill scenarios will not exceed the capacity of the AFS.

(This page intentionally left blank.)

APPENDIX ATTACHMENT D-4-3
REFERENCES

1

Date: October 2013 Revision No. 0

1

(This page intentionally left blank.)

Date: October 2013 Revision No. 0

1	APPENDIX ATTACHMENT D-4-3
2	REFERENCES
3	
4	
5	American National Standards Institute (ANSI) N-511-1989, Testing of Nuclear Air Cleaning System,
6	1989.
7	
8	Fedele, P., P. Georgopoulos, P. Shade, P. Lioy, M. Hodgson, and M. Brown, In-hospital Response to
9	External Chemical Emergencies: Personal Protective Equipment, Training, Site Operations Planning,
10	and Medical Programs, para. 3.5, pg. 11, 15 April 2003.
11	
12	Mahle, J., L. Buettner, and T. Sewell, Edgewood Chemical Biological Center, Draft, Umatilla
13	Post-Treatment Filter Simulant Performance for Candidate Mercury Capture Absorbents, 2008.
14	
15	Program Manager for Chemical Demilitarization, X-Ray Assessment of 155mm Mustard Projectiles
16	Stored at BGCA, Richmond, KY, 2011.
17	
18	SciTech Services Inc., Old Chemical Weapons Reference Guide, 1998.

(This page intentionally left blank.)

Revision No. 0

1	SECTION D
2	PROCESS DESCRIPTION
3	[6 CCR 1007-3 § 100.41(a)(8)]
4	
5	D.1 Overview
6	
7	The Pueblo Chemical Agent-Destruction Pilot Plant (PCAPP) Explosive Destruction System (EDS)
8	operations will contain two EDS units and a Container Storage Unit (CSU).
9	
10	An EDS is a transportable system designed to safely treat/destroy munitions and other items that contain
11	chemical agent fills with or without energetic components. The system uses explosive shaped charges to
12	detonate a munition burster, if present, and breach the munition/item wall, exposing the chemical fill.
13	Once the chemical fill is exposed, an appropriate treatment reagent is added to treat the chemical fill and
14	explosive residues. Mixing with heating follows, if required. After the chemical fill is treated, and the
15	treatment level confirmed, the resulting neutralent is drained into a liquid waste container, and the
16	Containment Vessel is rinsed. After the rinsate is drained into a waste container, the vessel is purged with
17	an inert gas and a headspace vapor sample is collected; once the vapor concentration is less than 1 vapor
18	screening level (VSL) or an acceptable value, the Containment Vessel door is opened. Solid waste
19	materials are then removed from the Containment Vessel and placed in appropriate solid waste
20	containers. All wastes are then stored pending shipment to a permitted treatment, storage, and disposal
21	facility (TSDF) for further treatment or ultimate disposal.
22	
23	The EDS units will be deployed to treat/destroy overpacked munitions, Department of Transportation
24	(DOT) cylinders, and other miscellaneous items (ignition cartridges, propellant) currently stored at
25	Pueblo Chemical Depot (PCD) that contain mustard agents (distilled sulfur mustard [HD]/mustard-T
26	mixture [HT]), as well as to treat/destroy any reject chemical agent munitions or contaminated bursters
27	generated from PCAPP operations.
28	
29	The CSU is an existing earth-covered concrete storage igloo that will be used to store items pending
30	treatment in an EDS. The overpacked munitions and miscellaneous items may or may not contain
31	energetics.

D-1 PCAPPEDSR0.D

DOT cylinders may or may not be in overpacks.

Date: October 2013 Revision No. 0

1 This section presents a general overview of the EDS treatment process. Physical descriptions and other

- 2 information on the CSU and EDS units are provided in Sections D-1 and D-11 of this permit
- 3 modification, respectively.

4 5

D.2 EDS Flow Process

6

7 A simplified block flow diagram of the EDS operation is presented in **Figure D-1**.²

8

D.2a PCAPP EDS Site Operations

10

- Overpacked munitions, DOT cylinders, and other miscellaneous items that contain or are contaminated
- with mustard agent (HD/HT) will be transferred from the PCD storage area to the CSU at the PCAPP
- EDS site for storage pending treatment. The CSU will hold up to a maximum of 300 munitions and DOT
- 14 cylinders.

15

- 16 Each EDS unit can be operated to treat one or more munitions or items simultaneously. Treatment
- 17 configurations may include one to six or more munitions or other chemical-agent items in each EDS unit
- 18 per process cycle, provided the net explosive weight (NEW) does not exceed the value established for the
- 19 particular EDS unit.

20

- Table D-1³ identifies the chemical fill, associated treatment reagent, and treatment level for EDS
- 22 operations at the PCAPP EDS site.

23

24 A brief discussion of the EDS operational steps follows.

2526

D.2a(1) Staging Munitions and Other Items

- 28 Items to be treated will be brought from the CSU and staged in the unpack area of an Environmental
- 29 Enclosure. Items contained in a universal munition storage container (UMSC) will be treated in an EDS
- in their entirety. The items (munitions and/or DOT cylinders) will not be removed from the overpack.
- 31 The munitions and miscellaneous items in other overpacks and containers, respectively, will be unpacked
- 32 and placed into special holders before they are placed into an EDS. Dunnage will be containerized,
- headspace monitored for agent, and shipped offsite for treatment and/or disposal.

_

All figures are located at the end of this section.

All tables are located at the end of this section.

le:	OC	lobe	1 2	UI	3
]	Revi	sior	ı N	o.	0

1	D.2a(2)	Place Item(s) in Advanced Fragment Suppression System (AFSS) and Attach Explosive	
2		Shaped Charges	
3			
4	Depending	on the types and numbers of items being treated, the items to be processed will be put into an	
5	expendable	e metal holder then placed inside the reusable AFSS with expendable steel rods.	
6			
7		work serves to connect, hold, and align explosive charges that open the main body of items	
8	•	ed to expose chemical fill and to protect the Containment Vessel interior from the high velocity	
9	fragments resulting during detonation of shaped charges, burster casing, and munitions (or other items).		
10			
11	Once shaped charges are attached, a final detonator connection is made; then the Containment Vessel		
12	door will be closed and sealed.		
13			
14	D.2a (3)	Periodic Helium Leak Test	
15	A 1 1' 1		
16		eak test is periodically conducted to confirm the integrity of the vessel seal. The helium leak	
17	detector is	used at that time to test the adequacy of the Containment Vessel door seals.	
18 19	D.2a(4)	Access Item and Destroy Burster (If Present)	
20	D.2a(4)	Access tem and Destroy Burster (II I resent)	
21	Once the s	eal is confirmed, the firing system is used to remotely and simultaneously initiate the shaped	
22		nusing the burster, if present, to detonate.	
23	charges, co	asing the surster, it present, to detonate.	
24	D.2a(5)	Treat Chemical Fill and Un-reacted Explosive Residues	
25		•	
26	Following	detonation, a treatment reagent will be pumped/sprayed into the Containment Vessel. The	
27	Containment Vessel will be heated by injecting steam, if necessary, to a specified temperature of up to		
28	60°C ±10°	C [140°F ±18°F]. The Containment Vessel will be rotated to agitate the contents of the vessel,	
29	promoting	mixing between chemical fill and reagent for a complete reaction. Containment Vessel	
30	temperatur	re and pressure will be monitored during the treatment process.	
31			
32	D.2a (6)	Sample Liquid Wastes (Neutralent)	
33			
34	A liquid sa	imple will be collected from the Containment Vessel to monitor the progress of the reaction or	
35	confirm tre	eatment is complete. Once the treatment level (Table D-1) is achieved, liquid wastes	

Date: October 2013 Revision No. 0

1 (neutralent) will be drained from the Containment Vessel into a waste container, then transferred to a less

2 than 90-day hazardous waste storage area.

3

D.2a(7) Rinse with Water and Steam

5

- 6 Following reagent drain, a water rinse is pumped/sprayed into the Containment Vessel. The Containment
- 7 Vessel is heated by injecting steam to a specified temperature of up to $100^{\circ}\text{C} \pm 10^{\circ}\text{C} \ [212^{\circ}\text{F} \pm 18^{\circ}\text{F}]$. The
- 8 Containment Vessel will be rotated to agitate the contents of the vessel and maintained at a temperature of
- 9 up to 100° C $\pm 10^{\circ}$ C for a required time to ensure clearing of the vessel interior. After rotation for the
- 10 required time, the Containment Vessel rinsewaters will be drained into an interim holding tank (a less
- than 90-day hazardous waste storage tank), cooled, then transferred to a waste container.

12

- Following the first rinsewater drain, a chilled water rinse is pumped/sprayed into the Containment Vessel.
- The Containment Vessel is cooled to temperatures around $60^{\circ}\text{C} \pm 10^{\circ}\text{C} [140^{\circ}\text{F} \pm 18^{\circ}\text{F}]$. After rotation for
- 15 cooling, the rinsewater is drained directly into a waste container.

16 17

D.2a(8) Flush Vapors and Sample Headspace

18

- 19 The Containment Vessel headspace will be flushed with an inert gas (e.g., helium or nitrogen) to the
- 20 carbon filter and then a headspace vapor sample will be collected from the vessel.

21

D.2a(9) Remove Solid Wastes

2223

- Once the vapor concentration is less than 1 VSL or an acceptable value, the Containment Vessel door will
- be opened. The solid wastes will be visually inspected for any unexploded energetic material, and then
- 26 manually removed from the vessel and placed into waste containers for solid waste.

2728

D.2a(10) Rinse Containment Vessel with Water

29

- 30 Once the solid wastes are removed, the Containment Vessel will then be manually rinsed with water to
- 31 remove any remaining debris. This rinsewater will be collected from the vessel into a debris pan placed
- 32 underneath the Containment Vessel. The rinsewater will then be transferred from the debris pan into a
- 33 waste container. Any remaining solid materials will be placed into a solid waste drum. Both liquid and

D-4

- 34 solid wastes will be transferred to a less than 90-day hazardous waste storage area pending shipment
- offsite to a permitted TSDF for further treatment or ultimate disposal.

1	D.2a(11) Prepare for Next Item(s)		
2			
3	Prior to treating subsequent chemical-filled items, the Containment Vessel interior and door will be		
4	cleaned using household bleach, general-purpose detergent, or other designated cleaning fluid, and the		
5	interior wall of the vessel, its sealing surface, and its door will be visually inspected. The Containment		
6	Vessel door metal seal and O-ring will be replaced after each operation. The electrical connection		
7	feedthroughs will be replaced as necessary. Both liquid and solid wastes will be transferred to a less than		
8	90-day hazardous waste storage area pending shipment offsite to a permitted TSDF for further treatment		
9	or ultimate disposal.		
10			
11	D.3 Waste Management		
12			
13	Wastes generated from the EDS treatment operation will be managed at the PCAPP EDS site less than		
14	90-day hazardous waste storage area (H1103) pending shipment to a permitted TSDF.		
15			
16	A detailed description of the waste streams, including applicable waste codes, is presented in Section C,		
17	Waste Characteristics.		
18			
19	D.4 Utilities and Site Support Equipment at PCAPP EDS Site		
20			
21	A description of utilities and site support equipment is provided in Attachment D-1 .		

Date: October 2013 Revision No. 0




Figure D-1. Simplified Block Flow Diagram for the EDS

PCAPPEDSR0.D D-6

Table D-1. Chemical Fills, Treatment Reagents, and Treatment Levels 1

2

Chemical Fill	Treatment Reagent	Treatment Level ^a
Sulfur Mustards (HD/HT) ^b	90 vol.% MEA	≤ 50 mg/L mustard agent

Notes:

When treating chemical agent fills, the neutralent and rinsewaters must meet the treatment level shown.

HD/HT will be measured as H.

8 MEAmonoethanolamine 10 mg/L = milligram per liter volume percent 11 vol.%

Date: October 2013 Revision No. 0

1

(This page intentionally left blank.)